

# DIRECT AC-AC CONVERTERS USING SWITCHING MODULES

C. A. Petry<sup>1</sup>, J. C. Fagundes<sup>2</sup>, I. Barbi<sup>3</sup>

Power Electronics Institute - INEP  
Dept. of Electrical Engineering - EEL  
Federal University of Santa Catarina – UFSC  
P. O. box 5119 – 88040-970 – Florianópolis – SC- Brazil  
(<sup>1</sup>petry, <sup>2</sup>fagundes, <sup>3</sup>ivobarbi)@inep.ufsc.br

**Abstract** – In this paper the study of direct AC-AC converter topologies, which make use of switches in commercial settings, will be performed. Several topologies are presented, including some already known in the literature and new ones. For one of the presented topologies, the design of a 3 kVA line conditioner is developed and experimental results are shown, certifying the correct operation of the drive strategy used.

**Keywords** – direct converters, AC-AC converters, line conditioner, switching modules.

## I. INTRODUCTION

Line conditioners are equipment used in industrial, residential and commercial environments in order to regulate the voltage provided by the grid. One of the main difficulties of employing alternating current converters using fast switches and PWM has always been the switching, which remained without a solution for many years. Observing Fig. 2 it can be seen that in order to switch from  $S_1/S_3$  to  $S_2/S_4$  there are two alternatives: the superposition of the drive signals or the use of dead-time. In the first case, a short-circuit in the voltage source is provoked, while in the second case the current through inductor  $L_o$  is interrupted, resulting in overvoltages across the switches [14].

One solution for the switching problem is the use of indirect converters [1], which inconveniently use a larger number of switches than direct converters.

A switching proposal for AC-AC converters was presented in [2] and improved in [3-7], eliminating the need for clamping circuits. In this switching strategy it is necessary to synchronize the drive signals with the converter's input voltage signal.

In [8] a switching cell was proposed for direct AC-AC converters, studied later in [9]. These converters are robust, with few controlled switches and solve the switching problem. However, there is a problem with average current through the inductors and switches cannot be used in commercial configurations.

The arrangement of the switches in commercial configurations for AC-AC converters were proposed in [4-7, 10]. These arrangements allow the use of commercial modules, an attractive feature especially at high power.

The main idea of this work is to employ the switching strategies of [3-7] in several topologies, among which some are well known and others are new, always using switches arranged in a way that permits the usage of commercial modules [4-7, 10].

In [11] several converters topologies were proposed, however, the main focus was neither on switching nor on the commercial arrangement of the switches. In this manner, among the topologies presented in this paper, one was chosen to implement a 3 kVA line conditioner, controlled by the orthogonal detection principle [12, 13].

## II. ORIGIN AND COMMUTATION OF THE PROPOSED TOPOLOGIES

To show the origin of the topologies that are going to be presented, an AC-AC Buck converter in a standard configuration will be shown, as depicted in Fig. 2. Note that this converter is bidirectional in both voltage and current by using commercial switches. However, the usage of commercial modules is not possible. Altering the position of switch  $S_3$ , a configuration which allows the usage of commercial modules is obtained, as shown in Fig. 3.

The switching is performed as shown in Fig. 1; note that during the positive semi-cycle of the grid voltage, switches  $S_3$  and  $S_4$  conduct and switches  $S_1$  and  $S_2$  are driven by PWM. During the negative semi-cycle of the grid voltage, switches  $S_1$  and  $S_2$  conduct and switches  $S_3$  and  $S_4$  are modulated at high-frequency.

## III. PROPOSED TOPOLOGIES

Using the same procedure adopted in Fig. 2, that is, rearranging the switches in a way to obtain configurations that allow the usage of commercial modules, several AC-AC converter topologies can be obtained. With these topologies several voltage compensating AC voltage conditioners can be implemented, which have the advantage of processing just the difference between the desired output voltage and the input voltage, consequently, processing just part of the load's power, guaranteeing a high performance. The static gain will be expressed as a function of the switches' duty-cycle and the turns ratios, for the structures that use transformers.




Fig. 1 – Switching of the converter switches of Fig. 3.

In Fig. 4 the full-bridge AC-AC converter is shown, while Fig. 6 and 7 depict the line conditioners based on the converter shown in Fig. 4.

Figures 8 and 12 illustrate converters based on the half-bridge converter, shown in Fig. 5. Note that the transformer has two secondary windings and not just a tap, generally used in the conventional converters [9]. This modification is performed so that switches in a modular configuration can be used.




Fig. 2 – Standard AC-AC Buck converter.




Fig. 3 – AC-AC Buck converter modified for the use of commercial switch modules.




Fig. 4 – Full-bridge converter.




Fig. 5 – Half-bridge converter.




Fig. 6 – Full-bridge conditioner supplied on the line side.




Fig. 7 – Full-bridge conditioner supplied on the load side.




Fig. 8 – Half-bridge conditioner supplied on the load side.




Fig. 9 – Push-pull converter.




Fig. 10 – Push-Pull conditioner supplied on the line side.




Fig. 11 – Push-Pull conditioner supplied on the load side.




Fig. 12 – Half-bridge conditioner supplied on the line side – implemented conditioner.

Table 1

| Figure | Converter  | Static gain   | Turns ratios  |
|--------|--|---|---|
| 2      | Buck   | $\frac{v_o}{v_i} = D$   | -   |
| 4      | Full-bridge - 2 levels                                       | $\frac{v_o}{v_i} = 2 \cdot D - 1$   | -   |
|        | Full-bridge - 3 levels                                       | $\frac{v_o}{v_i} = D$   |   |
| 6      | Full-bridge conditioner supplied on the line side – 2 levels | $\frac{v_o}{v_i} = 1 + \frac{2 \cdot D - 1}{n}$                                     | $n = \frac{1 - \Delta}{\Delta}$   |
|        | Full-bridge conditioner supplied on the line side – 3 levels | $\frac{v_o}{v_i} = 1 + \frac{D}{n}$   |   |
| 7      | Full-bridge conditioner supplied on the load side – 2 levels | $\frac{v_o}{v_i} = \frac{1}{1 - \frac{2 \cdot D - 1}{n}}$                           | $n = \frac{1}{\Delta}$  |
|        | Full-bridge conditioner supplied on the load side – 3 levels | $\frac{v_o}{v_i} = \frac{1}{1 - \frac{D}{n}}$                                       |   |
| 5      | Half-bridge  | $\frac{v_o}{v_i} = \frac{D \cdot (n_a + n_b) - n_a}{n_a \cdot n_b}$                 | -   |
| 12     | Half-bridge conditioner supplied on the line side            | $\frac{v_o}{v_i} = \frac{D \cdot (n_a + n_b) + n_a \cdot n_b - n_a}{n_a \cdot n_b}$ | $n_a = \frac{1 - \Delta}{\Delta} \quad n_b = \frac{1 + \Delta}{\Delta}$ |
| 8      | Half-bridge conditioner supplied on the load side            | $\frac{v_o}{v_i} = \frac{n_a \cdot n_b}{n_a \cdot n_b + n_a - D \cdot (n_a + n_b)}$ | $n_a = n_b = \frac{1}{\Delta}$  |
| 9      | Push-pull  | $\frac{v_o}{v_i} = \frac{D \cdot (n_a + n_b) - n_a}{n_a \cdot n_b}$                 | -   |
| 10     | Push-Pull conditioner supplied on the line side              | $\frac{v_o}{v_i} = \frac{D \cdot (n_a + n_b) - n_a + n_a \cdot n_b}{n_a \cdot n_b}$ | $n_a = \frac{1 - \Delta}{\Delta} \quad n_b = \frac{1 + \Delta}{\Delta}$ |
| 11     | Push-Pull conditioner supplied on the load side              | $\frac{v_o}{v_i} = \frac{n_a \cdot n_b}{n_a \cdot n_b + n_a - D \cdot (n_a + n_b)}$ | $n_a = n_b = \frac{1}{\Delta}$  |

Table 1 summarizes the proposed topologies and the static gain expressions for all the converters and the turns ratios for the structures that use transformers.

#### IV. IMPLEMENTED CONDITIONER AND EXPERIMENTAL RESULTS

##### A. Converter design

The line conditioner which will be implemented in the laboratory with the objective of certifying the operation of the proposed topologies is the converter shown in Fig. 12. This is a half-bridge converter which uses a transformer with two secondary windings and four controlled switches.  $L_o$  and  $C_o$  compose the converter's output filter. Voltage compensation, with proper amplitude and phase, is applied in series with the input voltage so that the output voltage has the correct amplitude.

The duty-cycle ( $D$ ) is defined as the ratio between the conducting interval of switches  $S_1$  and  $S_2$  and the total period ( $T_s = 1/f_s$ ), considering the positive semi-cycle of the grid

voltage. During the negative semi-cycle, the duty-cycle is the ratio between the conducting intervals of switches  $S_3$  and  $S_4$  and the total time, given by the switching frequency ( $f_s$ ).

The expression for the static gain is again described in (1). The turns ratios ( $n_a$  and  $n_b$ ) of transformer  $T_1$  are given as a function of the voltage variation permitted at the input ( $\Delta$ ) and shown in (2). In (3) the expression for the ripple current of inductor  $L_o$  is shown and (4) describes the ripple voltage of capacitor  $C_o$ .

$$\frac{V_o}{V_i}(\Delta, D) = \frac{\Delta \cdot (1 - 2 \cdot D) - 1}{(1 + \Delta) \cdot (1 - \Delta)} \quad (1)$$

$$n_a = \frac{1 - \Delta}{\Delta} \quad n_b = \frac{1 + \Delta}{\Delta} \quad (2)$$

$$\Delta i_{L_o} = \frac{V_o}{f_s \cdot L_o} \frac{-2 \cdot D \cdot (D - 1) \cdot \Delta}{1 - \Delta + 2 \cdot D \cdot \Delta} \quad (3)$$

$$\Delta v_{C_o} = \frac{4}{\pi^3 \cdot f_s \cdot C_o} \Delta i_{L_o} \quad (4)$$

Using the above mentioned expressions, a conditioner with the following parameters was designed:

- $v_i = 220 \pm 20\% V$ ,  $v_o = 220 V$ ,  $S_o = 3 kVA$
- $f_s = 20 kHz$ ,  $n_a = 3.2$ ,  $n_b = 4.8$ ,  $C_o = 10 \mu F$
- $L_o = 400 \mu H$ ,  $S_1$  to  $S_4 = IRG4PSC71UD$

Fig. 12 illustrates the simplified circuit of the implemented conditioner. In this figure, note that the output voltage is sampled in order to generate the synchronism signals in order to properly obtain the drive signals of the switches, according to the input/output voltage's polarity. The control technique using orthogonal detection is also shown and the voltage compensator is a classic proportional-integral [12, 13].

### B. Experimental results

In Fig. 13 the drive signals (at low frequency) of switches  $S_1$  and  $S_2$  are shown along with the synchronism signal. Note that during the positive semi-cycle these switches are controlled by means of PWM, while during the negative semi-cycle they conduct continuously. In the same manner, Fig. 14 illustrates the drive signals of  $S_3$  and  $S_4$ .

Figure 15 shows the voltages across switches  $S_1$  and  $S_3$  without overvoltages, demonstrating the proper operation of the drive strategy used here. The input and output voltages are shown in Fig. 16, note that for an input of -10%, the output voltage is being stabilized at 220 V, as desired.




Fig. 13 – Drive signals of switches  $S_1$  and  $S_2$ .




Fig. 14 – Drive signals of switches  $S_3$  and  $S_4$ .




Fig. 15 – Voltages across switches  $S_1$  and  $S_3$ .




Fig. 16 – Input and output voltages - ( $v_i = 0.9 \cdot v_o$ ).




Fig. 17 – Input and output voltages - ( $v_i = v_o$ ).

In Fig. 17 the input and output voltages are shown for line voltage at 220 V. In this case the duty cycle is 0.4.

Finally, figure 18 shows the input and output voltages for a line voltage at 242 V, so the duty cycle is 0.225.

Observing Figs. 16 to 18 it can be noticed that the control voltage is continuous during all the line voltage period, characteristic of direct AC-AC converters.




Fig. 18 – Input and output voltages - ( $v_i = I \cdot I \cdot v_o$ ).

## V. CONCLUSIONS

In this paper several topologies for direct AC-AC converters, which permit using commercial switch modules, were presented. From these topologies line conditioners were proposed, among which one was chosen for implementation as a laboratory prototype. The experimental results of this prototype were shown, demonstrating the proper operation of the drive strategy as well as orthogonal detection control.

The main expressions for the half-bridge conditioner were presented as well as the origin of the proposed topologies.

The possibility of using commercial modules makes the studied topologies attractive for high power applications, either as voltage conditioners or reactive, harmonics, sags and overvoltage compensators, among others.

## ACKNOWLEDGEMENT

The authors would like to thank CNPq for their financial support and Luis C. Tomaselli, Telles B. Lazzarin and André L. Fuerback for their contributions in assembling the laboratory prototype.

## REFERENCES

- [1] C. A. Petry, J. C. Fagundes, I. Barbi. *AC-AC Indirect Converter for Application as Line Conditioner*. 7<sup>th</sup> Brazilian Power Electronics Conference (COBEP'2003), Fortaleza, CE - Brazil, p. 509-514, Setembro 2003.
- [2] P. N. Enjeti, S. Choi. *An approach to realize higher power PWM AC controller*. Applied Power Electronics Conference and Exposition (APEC'93), p. 323-327, March 1993.
- [3] E. P. Trabach, P. F. S. Amaral, et al. *A Stabilized Single Phase Electronic Autotransformer*. 5<sup>nd</sup> Brazilian Power Electronics Conference (COBEP'99), Foz do Iguaçu, PR - Brazil, p. 701-706, Setembro 1999.
- [4] B.-H. Kwon, B.-D. Min, J.-H. Kim. *Novel topologies of AC choppers*. IEE Proceedings Electric Power Applications, p. 323-330, July 1996.
- [5] J.-H. Kim, B.-D. Min, et al. *A PWM Buck-Boost AC Chopper Solving the Commutation Problem*. IEEE Transactions on Industrial Electronics, Vol. 45, n. 5, p. 832-835, October 1998.
- [6] J.-H. Kim, B.-H. Kwon. *Three-phase ideal phase shifter using AC choppers*. IEE Proceedings Electric Power Applications, p. 329-335, July 2000.
- [7] T. Shinyama, A. Ueda, A. Torri. *AC chopper using four switches*. Proceedings of the Power Conversion Conference (PCC 2002), p. 1056-1060, April 2002.
- [8] J. C. Fagundes, E. V. Kassick, I. Barbi. *A PWM AC Chopper Without Dead Time and Clamping Circuit*. 2<sup>nd</sup> Brazilian Power Electronics Conference (COBEP'93), Uberlândia, MG - Brazil, p. 302-307, November 1993.
- [9] C. A. Petry, J. C. Fagundes, I. Barbi. *High Frequency AC Regulator for Non-Linear Loads*. 6<sup>th</sup> Brazilian Power Electronics Conference (COBEP'2001), Florianópolis, SC - Brazil, p. 491-496, Novembro 1999.
- [10] G. Venkataramanan. *A family of PWM converters for three phase AC power conditioning*. International Conference on Power Electronics, Drives and Energy Systems for Industrial Growth, p. 572-577, January 1996.
- [11] Z. Fedyczak, R. Strzelecki, G. Benysek. *Single-phase PWM AC/AC semiconductor transformer topologies and applications*. 33<sup>rd</sup> Annual IEEE Power Electronics Specialists Conference (PESC'02), p. 1048-1053, June 2002.
- [12] H.-Y. Chu, H.-L. Jou, C.-L. Huang. *Transient Response of a Peak Voltage Detector for Sinusoidal Signals*. IEEE Transactions on Industrial Electronics, Vol. 39, n. 1, p. 74-79, February 1992.
- [13] C.-T. Pan, M.-C. Jiang. *A Quick Response Peak Detector for Variable Frequency Three-Phase Sinusoidal Signals*. IEEE Transactions on Industrial Electronics, Vol. 41, n. 4, p. 434-440, August 1994.
- [14] H. Kragh. *On the control of a DC-link based high frequency AC-voltage regulator*. IEEE Power Electronics Specialists Conference (PESC'01), p. 1122-1128, June 2001.