

A FAST INSTANTANEOUS METHOD FOR SEQUENCE EXTRACTION

Rodrigo Cutri^{1,2} / Lourenço Matakas Junior^{1,3,4}

¹USP – University of São Paulo, São Paulo, BRAZIL

²IMT – Mauá Institute of Technology - Mauá School of Engineering – E.E.Mauá

³Pontificia Univ. São Paulo ; ⁴Univ. S Judas Tadeu;

Abstract –Harmonics and unbalance causes several problems to equipments connected in AC mains. This work proposes a real time method to obtain the positive and negative sequence components and/or harmonics that require nor coordinate transform neither signal filtering. Numerical simulation and experimental results are showed to validate the proposed method.

Keywords – active filters, harmonics, power quality, sequence extraction, protection relays

I. INTRODUCTION

Distorted and unbalanced voltages/currents in electric systems cause several negative effects in power systems [7],[12], [23]-[29],[35],[36].

Real time extraction of unbalances and/or or harmonics is demanded in some applications like active compensators and protective relays. Many strategies were developed for unbalanced components and/or harmonics extraction [1]-[4], [6], [8], [9], [11], [13]-[18], [20], [21], [22], [26], [28], [29], [31], [32],[34] and [35]. Among them, the well known methods are: positive synchronous reference frame (RSP) and negative synchronous reference frame (RSN) [8], [26], the real time detection using space vectors (DTRVE) [32], the instantaneous active and reactive theory (PQ) [2],[30] and the direct injection of negative sequence (DSNI) [9]. A comparative study about some of these strategies is done by [5], [10] and [19].

This paper is based on the work developed by [10],[34]. It proposes an algorithm based on the “symmetrical components theory” that requires nor coordinate transform neither signal filtering. It uses only algebraic calculations. This method allows extracting only the fundamental positive and/or negative sequence and/or harmonics (section 3). Experimental results using Matlab - Simulink software and Analog DSP ADMC401 are presented (section 4).

II. APPLICATIONS OF THE PROPOSED METHOD

The proposed algorithm can extract positive, negative sequence and harmonics components of a corrupt signal and be applied to active power filters, dynamic voltage restorers, power quality analyzers and protective relays systems.

III. PROPOSED METHOD FOR CALCULATING THE INSTANTANEOUS REFERENCE

A. Algorithm description

Eq. (1) calculates the phasors of the symmetrical components ($\dot{S}_0, \dot{S}_+, \dot{S}_-$) of a set of three phase signals (current or voltage) ($\dot{S}_R, \dot{S}_S, \dot{S}_T$) [24] and [33]:

$$\begin{bmatrix} \dot{S}_0 \\ \dot{S}_+ \\ \dot{S}_- \end{bmatrix} = \frac{1}{3} \underbrace{\begin{bmatrix} 1 & 1 & 1 \\ 1 & 1\angle 120^\circ & 1\angle -120^\circ \\ 1 & 1\angle -120^\circ & 1\angle 120^\circ \end{bmatrix}}_M \begin{bmatrix} \dot{S}_R \\ \dot{S}_S \\ \dot{S}_T \end{bmatrix} = \mathbf{M} \begin{bmatrix} \dot{S}_R \\ \dot{S}_S \\ \dot{S}_T \end{bmatrix} \quad (1)$$

Zero sequence signals can be extracted using (2). To get the unbalanced signals, in three-phase three wire systems, it is necessary to separate the negative sequence (3).

$$\begin{bmatrix} \dot{S}_0 \\ 0 \\ 0 \end{bmatrix} = \frac{1}{3} \begin{bmatrix} 1 & 1 & 1 \\ 0 & 0 & 0 \\ 0 & 0 & 0 \end{bmatrix} \begin{bmatrix} \dot{S}_R \\ \dot{S}_S \\ \dot{S}_T \end{bmatrix} \quad (2) \quad \begin{bmatrix} 0 \\ 0 \\ \dot{S}_- \end{bmatrix} = \frac{1}{3} \begin{bmatrix} 0 & 0 & 0 \\ 0 & 0 & 0 \\ 1 & 1\angle -120^\circ & 1\angle 120^\circ \end{bmatrix} \begin{bmatrix} \dot{S}_R \\ \dot{S}_S \\ \dot{S}_T \end{bmatrix} \quad (3)$$

To obtain the desired signals in rst frame it is necessary to multiply the signals of (3) by the inverse matrix (\mathbf{M}^{-1}) from (1), so obtain (4).

$$\begin{bmatrix} \dot{S}_{ref_r-} \\ \dot{S}_{ref_s-} \\ \dot{S}_{ref_t-} \end{bmatrix} = \mathbf{M}^{-1} \cdot \frac{1}{3} \begin{bmatrix} 0 & 0 & 0 \\ 0 & 0 & 0 \\ 1 & 1\angle -120^\circ & 1\angle 120^\circ \end{bmatrix} \begin{bmatrix} \dot{S}_R \\ \dot{S}_S \\ \dot{S}_T \end{bmatrix} = -\frac{1}{3} \begin{bmatrix} -1 & 1\angle 60^\circ & 1\angle -60^\circ \\ 1\angle -60^\circ & -1 & 1\angle 60^\circ \\ 1\angle 60^\circ & 1\angle -60^\circ & -1 \end{bmatrix} \begin{bmatrix} \dot{S}_R \\ \dot{S}_S \\ \dot{S}_T \end{bmatrix} \quad (4)$$

The matrix operation showed in (4) can be divided into two matrixes: the first one contains the real terms and second one the imaginary terms multiplied by $-j$, according (5).

$$\begin{bmatrix} \dot{S}_{ref_r-} \\ \dot{S}_{ref_s-} \\ \dot{S}_{ref_t-} \end{bmatrix} = \frac{1}{3} \left[-\begin{bmatrix} -1 & 1/2 & 1/2 \\ 1/2 & -1 & 1/2 \\ 1/2 & 1/2 & -1 \end{bmatrix} - j \begin{bmatrix} 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \\ -\frac{\sqrt{3}}{2} & 0 & \frac{\sqrt{3}}{2} \\ \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} & 0 \end{bmatrix} \right] \begin{bmatrix} \dot{S}_R \\ \dot{S}_S \\ \dot{S}_T \end{bmatrix} \quad (5)$$

For steady state operation ([10],[34],[37]) the phasor equations (4) and (5) can be rewritten in time domain, resulting in (6) and (7). The phase shift of 60° (-60°) or -90° (90°) can be implemented by time delaying the original signals by a time interval corresponding to the desired angles at the fundamental frequency. The time delaying can be implemented by saving a determined number of samples. The delay of 90° (signals ($s_{r-90}(t)$, $s_{s-90}(t)$, $s_{t-90}(t)$)) can be implemented by saving the last $N/4$ measured samples. The

advance of 90° is accomplished by the delayed signals multiplied by -1. The delay of 60° ($s_{r-60}(t)$, $s_{s-60}(t)$, $s_{t-60}(t)$) can be accomplished by saving the last N/6 measured samples. The 60° phase advanced signals ($s_{r60}(t)$, $s_{s60}(t)$, $s_{t60}(t)$) can be obtained by using the last N/3 measured and saved samples, equivalent to a delay of -120°, with opposite signal. (N is the number of samples per period, at the fundamental frequency).

$$\begin{bmatrix} s_{r+}(t) \\ s_{s+}(t) \\ s_{t+}(t) \end{bmatrix} = -\frac{1}{3} \begin{bmatrix} -1 & 0 & 0 \\ 0 & -1 & 0 \\ 0 & 0 & -1 \end{bmatrix} \begin{bmatrix} s_r(t) \\ s_s(t) \\ s_t(t) \end{bmatrix} + \begin{bmatrix} 0 & 1 & 0 \\ 0 & 0 & 1 \\ 1 & 0 & 0 \end{bmatrix} \begin{bmatrix} s_{r-60}(t) \\ s_{s-60}(t) \\ s_{t-60}(t) \end{bmatrix} + \begin{bmatrix} 0 & 0 & 1 \\ 1 & 0 & 0 \\ 0 & 1 & 0 \end{bmatrix} \begin{bmatrix} s_{r60}(t) \\ s_{s60}(t) \\ s_{t60}(t) \end{bmatrix} \quad (6)$$

$$\begin{bmatrix} s_{r+}(t) \\ s_{s+}(t) \\ s_{t+}(t) \end{bmatrix} = \frac{1}{3} \begin{bmatrix} -1 & 1/2 & 1/2 \\ 1/2 & -1 & 1/2 \\ 1/2 & 1/2 & -1 \end{bmatrix} \begin{bmatrix} s_r(t) \\ s_s(t) \\ s_t(t) \end{bmatrix} + \begin{bmatrix} 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \\ -\frac{\sqrt{3}}{2} & 0 & \frac{\sqrt{3}}{2} \\ \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} & 0 \end{bmatrix} \begin{bmatrix} s_{r-90}(t) \\ s_{s-90}(t) \\ s_{t-90}(t) \end{bmatrix} \quad (7)$$

The same reasoning can be applied to calculate the positive sequence, only changing 60° (-60°) to -60°(60°) (8) or -90° (90°) (9).

$$\begin{bmatrix} s_{r+}(t) \\ s_{s+}(t) \\ s_{t+}(t) \end{bmatrix} = -\frac{1}{3} \begin{bmatrix} -1 & 0 & 0 \\ 0 & -1 & 0 \\ 0 & 0 & -1 \end{bmatrix} \begin{bmatrix} s_r(t) \\ s_s(t) \\ s_t(t) \end{bmatrix} + \begin{bmatrix} 0 & 1 & 0 \\ 0 & 0 & 1 \\ 1 & 0 & 0 \end{bmatrix} \begin{bmatrix} s_{r-60}(t) \\ s_{s-60}(t) \\ s_{t-60}(t) \end{bmatrix} + \begin{bmatrix} 0 & 0 & 1 \\ 1 & 0 & 0 \\ 0 & 1 & 0 \end{bmatrix} \begin{bmatrix} s_{r60}(t) \\ s_{s60}(t) \\ s_{t60}(t) \end{bmatrix} \quad (8)$$

$$\begin{bmatrix} s_{r+}(t) \\ s_{s+}(t) \\ s_{t+}(t) \end{bmatrix} = \frac{1}{3} \begin{bmatrix} -1 & 1/2 & 1/2 \\ 1/2 & -1 & 1/2 \\ 1/2 & 1/2 & -1 \end{bmatrix} \begin{bmatrix} s_r(t) \\ s_s(t) \\ s_t(t) \end{bmatrix} - \begin{bmatrix} 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \\ -\frac{\sqrt{3}}{2} & 0 & \frac{\sqrt{3}}{2} \\ \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} & 0 \end{bmatrix} \begin{bmatrix} s_{r90}(t) \\ s_{s90}(t) \\ s_{t90}(t) \end{bmatrix} \quad (9)$$

The operations defined by eqs. (6),(7),(8),(9) will be called as A, B, C, D respectively. Operations A and B provide the same result for the fundamental frequency. The same occurs for operation C and D. The methods were originally developed for the fundamental frequency. Harmonic components will present different behaviors according to their order and phase sequence for the operations A, B, C, D. Table I and Table II present the gain and phase (°) displacement resulting from the use of the operations A, B, C, D, and the cascaded cases A+B and C+D for odd and even harmonics respectively (positive and negative sequence).

TABLE I – Gain and angle (degrees) for operations A, B, C, D, A+B, C+D for odd harmonics, positive and negative sequences.

operation	A	B	C	D	A+B	C+D
1°seq+			1)0	1)0		1)0
1°seq-	1)0	1)0			1)0	
3°seq+		1)0				
3°seq-				1)0		
5°seq+	1)0			1)0		
5°seq-		1)0	1)0			


TABLE II – Gain and angle (degrees) for operations A, B, C, D, A+B, C+D for even harmonics, positive and negative sequences.

operation	A	B	C	D	A+B	C+D
2°seq+	$\frac{1}{3} \angle 0^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{2}{3} \angle -60^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{7}{30} \angle 45^\circ$	$\frac{14}{30} \angle -105^\circ$
2°seq-	$\frac{2}{3} \angle -60^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{1}{3} \angle 0^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{14}{30} \angle -105^\circ$	$\frac{7}{30} \angle 45^\circ$
4°seq+	$\frac{2}{3} \angle 60^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{1}{3} \angle 0^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{14}{30} \angle 15^\circ$	$\frac{7}{30} \angle 45^\circ$
4°seq-	$\frac{1}{3} \angle 0^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{2}{3} \angle 60^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{7}{30} \angle 45^\circ$	$\frac{14}{30} \angle 15^\circ$
6°seq+	$\frac{2}{3} \angle -60^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{2}{3} \angle 60^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{14}{30} \angle -15^\circ$	$\frac{14}{30} \angle 15^\circ$
6°seq-	$\frac{2}{3} \angle 60^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{2}{3} \angle -60^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{14}{30} \angle 15^\circ$	$\frac{14}{30} \angle -15^\circ$
8°seq+	$\frac{1}{3} \angle 0^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{2}{3} \angle -60^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{7}{30} \angle -45^\circ$	$\frac{14}{30} \angle -15^\circ$
8°seq-	$\frac{2}{3} \angle -60^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{1}{3} \angle 0^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{14}{30} \angle -15^\circ$	$\frac{7}{30} \angle -45^\circ$
10°seq+	$\frac{2}{3} \angle 60^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{1}{3} \angle 0^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{14}{30} \angle 105^\circ$	$\frac{7}{30} \angle -45^\circ$
10°seq-	$\frac{1}{3} \angle 0^\circ$	$\frac{7}{10} \angle -45^\circ$	$\frac{2}{3} \angle 60^\circ$	$\frac{7}{10} \angle 45^\circ$	$\frac{7}{30} \angle -45^\circ$	$\frac{14}{30} \angle 105^\circ$

For odd harmonics, operations A (C) presents the same gain for (1+6n) order positive sequence (neg. seq) harmonics (n=0,1,2,...) and for (5+6n) order negative sequence (pos.seq.). Operations B and (D) presents the same gain for (3+4n) seq+(-) and (1+4n)seq-(-) harmonics. The cascaded application of operations AB (CD) presents the same gain for (11+12n)seq+(-) and (1+12n)seq-(-) harmonics. For even harmonics, operations A and C presents the same gain for (2+6n), (4+6n) and (6+6n) harmonics. Operations B and D presents the same gain for (2+4n) and (4+4n) harmonics. Cascaded application of operations AB and CD presents the same gain for (2+12n), (4+12n), (6+12n), (8+12n), (10+12n) and (12+12n) harmonics. For all operations, even harmonics are not cancelled but only minimized. For additional attenuation, the operations blocks can be cascaded.

B. Strategies to separate the individual disturbances

A careful analysis of table I show that it is possible to combine operators (A, B, C, D) to obtain different compensation strategies (table III). Only odd harmonics are considered in the four cases. Case 1 shows how the positive sequence of the fundamental component can be extracted from harmonic corrupted, unbalanced signals, by the cascaded application of C and D operations. Similarly, Case 2 shows the extraction of the negative sequence signal by using A and B operations. It is suitable for calculating the reference signal of unbalance compensators. Case 3 extracts all the harmonic components and is suitable for using in harmonic filters. Case 4 extracts the negative sequence and harmonics.

TABLE III – DESIRED EXTRACTION

IV. SIMULATION AND EXPERIMENTAL RESULTS

The methods were simulated for each case showed in Table III, using the software MATLAB [37]. Transient response is presented in table IV [37]. Processing time (for ADC401) is presented in table V. Corrupted test signal is showed in (Fig.1) and steady state extracted signals for methods AB and CD are showed in Figs. (2), (3), (4) and (5).

TABLE IV – TRANSIENT RESPONSE (related to the period of the fundamental signal)

Method	A	B	C	D	AB	CD
Theory	1/3	1/4	1/3	1/4	3/5	3/5
Simulation	1/3	1/4	1/3	1/4	3/5	3/5
Experimental	1/3	1/4	1/3	1/4	3/5	3/5

Table V – Processing Time (for ADC401)

Method	A	B	C	D	AB	CD
Time (us)	7.6	9	7.6	9	15.4	15.4




Fig. 1 Test signal




Fig. 2 Negative sequence signal extracted by process AB




Fig. 3 Positive sequence Signal extracted by process CD

The proposed method assumes that the period of the signal is known, to generate the delayed signals ($s_{r-90}(t)$, $s_{s-90}(t)$, $s_{t-90}(t)$), ($s_{r-60}(t)$, $s_{s-60}(t)$, $s_{t-60}(t)$), ($s_{r60}(t)$, $s_{s60}(t)$, $s_{t60}(t)$). A PLL can be used to instantaneously track the signal period. If a PLL is not used, and a fixed period equal to the nominal value is used, errors may arise from this method. To verify the possibility of operation without PLL the frequency response for the case 2 (table III) was evaluated for 1, 3, 5, 7 harmonic components of the input signal (fig. 4). The amplitude error of the extracted fundamental negative sequence is quite small (2%) for a large variation (50 to 70 Hz) of the input signal. Phase delay, by the other side, is quite large (180 degrees for

50Hz), making this method not viable for some applications. The delays were based on a 60Hz signal.

Positive sequence is adequately attenuated (gain= 0,02 for 50Hz).

Harmonic components, which are expected to be fully cancelled by case 2 algorithm, have a poor attenuation for signal frequencies slightly far from 60Hz. Figure 5 presents the frequency response for case 1 (CD operation).

Operation without a PLL is only feasible for signals with small frequency variation, which occurs in equipment connected to strong, interconnected power systems. For weak systems, fed for example by Diesel-Generators, PLL-less operation is possible only for low distorted voltages and currents.

V. CONCLUSIONS

This paper proposes real time algorithms to extract any combination of positive, negative sequence and/or harmonics of a corrupted signal. The processing uses nor coordinate transform neither signal filtering. It can be easily implemented in a DSP, presents a good extraction performance, needs no filtering, has low numerical complexity and presents fast response (less than one fundamental period). It is suitable for many applications like, active power filters, dynamic voltage restorers, power quality analyzers, protective relay, and others. Operation for varying fundamental frequency and the use of PLL to estimate the signal period is discussed.




Fig. 4 Operation AB – Frequency Response of Case 2 for various harmonics and phase sequences
Upper: gain Lower: phase




Fig. 5 Operation CD – Frequency Response of Case 1 for various harmonics and phase sequences
Upper: gain Lower: phase

REFERENCES

- [1] ABELLÁN,A ;GARCERÁ,G. ;BENAVENT,J. A New Control Method for Obtaining Reference Currents of Shunt Active Power Filters in Unbalanced and Non-Sinusoidal Conditions. In:Industrial Electronics–ISIE'99 Proceedings of the IEEE International Symposium on,Jul.1999. Anais eletrônicos. v.2.
- [2] AKAGI,H. ;NABAE,A. The p-q Theory in Three-Phase Systems Under Non-Sinusoidal Conditions. ETEP, v.3, n.1, Jan. Feb. 1993.
- [3] BHAVARAJU,V.P. ;ENJETI,P.N. Analysis and Design of an Active Power Filter for Balancing Unbalanced Loads. IEEE Transactions on Power Electronics, v.8, n.4, Oct. 1993.
- [4] BRITTAIN,J.C. Charles F. Scott : A Pioneer in Electrical Power Engineering. IEEE Industry Applications Magazine, p.6-8. Nov. Dec. 2002.
- [5] CHANG,G.W. ;SHEE,T. A Comparative Study of Active Power Filter Reference Compensation Approaches. IEEE 2002 Power Engineering Society Summer Meeting, 21-25 July 2002. Anais, IEEE, v.2, p.1017-1021. 2002.
- [6] CHEN,C.C. ;HSU,Y. A Novel Approach to the Design of a Shunt Active Filter for an Unbalanced Three-Phase Four Wire System under Nonsinusoidal Conditions. In:Power Engineering Society Summer Meeting,Jul.2000. Anais eletrônicos. v.2. p.1059.
- [7] CHEN, Tsai-Hsiang. Criteria to estimate the Voltage Unbalances due to High-Speed Railway Demands. IEEE Transactions on Power Systems, v.9, n.3, Aug. 1994.

- [8] CHOI,S. ;LEE,W. ;HYUN,D. ;LEE, T. The Control system of the Active Power Filter Considering Power Factor in Unbalanced Load. In:Industry Applications Conference, Oct.2000. Anais eletrônicos. v.4. p.2123-2128.
- [9] CUTRI,R. ;MATAKAS JR.,L. Reference Currents Determination Techniques For Load Unbalance Compensation. In:7º Congresso Brasileiro de Eletrônica de Potência- COBEP'03,Fortaleza,Set.2003. CD-ROM
- [10] CUTRI,R. Compensação de desequilíbrios de carga empregando conversor estático operando com modulação em largura de pulso. 2004. Dissertação (Mestrado) -,Universidade de São Paulo. São Paulo.
- [11] CZARNECKI,L.S.Power Factor Improvement of Three-Phase Unbalanced Loads with Non-Sinusoidal Supply Voltage. ETEP, v.3, n°1, Jan. Feb. 1993.
- [12] E.E.STAFF DEL M.I.T. Circuitos Magnéticos Y Transformadores. Madri:Editorial Reverte S.A., 1965. p.638-640.
- [13] DIXON,J.W. ;GARCIA,J. ;MORÁN,T.L. A Control System for a Three Phase Active Power Filter which Simultaneously Compensates Power Factor and Unbalanced Loads. IEEE Transactions on Industrial Electronics, v.42, Issue:6, p.636-641. Dec. 1995.
- [14] HOCHGRAF,C. ;LASSETER,R. Statcom Controls for Operation with Unbalanced Voltages. IEEE Transactions on Power Delivery, v.13. n.2, Apr. 1998.
- [15] KIM,H. ;BLAABJERG,F. ;JENSEN,B.B. ;CHOI,J. Instantaneous Power Compensation in Three-Phase Systems by Using p-q-r theory. In:Power Electronics Specialists Conference,2001-PESC'2001- IEEE 32nd Annual,June.2001. Anais eletrônicos. v.2. p.478-485.
- [16] KIM,H. Control an Active Filter in Unbalanced Non-sinusoidal Source Voltages. In:Power Conversion Conference Proceedings of.,Osaka,Apr.2002. Anais eletrônicos. v.2. p.831-836. Acesso restrito disponível em:<periódicos IEEE-Capes>.
- [17] LEDWICH,G. ;GEORGE,T.A. Using Phasors to analyze power system negative phase sequence voltages caused by unbalanced loads. IEEE Transactions in Power Systems, v.9, n.3, Aug. 1994.
- [18] LIN,C.E. ; CHEN,C.L. ; HUANG,C.L. Calculating Approach and Implementation for active Filters in Unbalanced Three-Phase System using Synchronous Detection Method. In:Industrial Electronics,Control,Instrumentation and Automation – ‘Power Electronics and Motion Control’, Proceedings of the 1992 International Conference on,Nov.1992. Anais eletrônicos. v.1. p.374-380.
- [19] MARQUES,G.D. A Comparison of Active Filters Control Methods in Unbalanced and Non-sinusoidal Conditions. In:Industrial Electronics Society – IECON'98 Proceedings of the 24th Annual Conference of the IEEE,Aug.Sep.1998. Anais eletrônicos. v.1. p.444-449. Acesso restrito disponível em:<periódicos IEEE-Capes>.
- [20] MATSUI,M. ;FUKAO,T. A Detecting Method for Active-Reactive-Negative Sequence Powers and its Application. IEEE Transactions on Industry Applications, v.26, n.1, Jan. Feb. 1990.
- [21] MCGRANAGHAM,M. Active Filter Design and Specification for Control of Harmonics in Industrial and Commercial Facilities. Electrotek Concepts,Inc. Knoxville TN, USA. Disponível em:<<http://www.dranetz-bmi.com/pdf/activeFilter.pdf>>. Acesso em:2003.
- [22] NIKOLAENKO,V.G. Optimal Balancing of Large Unbalanced Loads Using Shunt Compensators. In:Harmonics and Quality of Power , Proceedings 8th International Conference on,Oct.1998. Anais eletrônicos. v.1. p.537-542.
- [23] PENTEADO JR., A.A. Compensadores estáticos para desequilíbrios : um procedimento de especificação e de análises das interferências no sistema elétrico. 1985. Tese (Doutorado) - Escola Politécnica,Universidade de São Paulo. São Paulo.
- [24] ROBBA, J. et al. Introdução a Sistemas Elétricos de Potência. 2ed. São Paulo:Edgard Blucher, 1996.
- [25] SAMESIMA, M.I. Compensadores Estáticos de Reativos e de Desequilíbrios em Sistemas Elétricos de Potência. 1984. Dissertação (Mestrado) – Escola Politécnica,Universidade de São Paulo. São Paulo.
- [26] SENINI,S. ;WOLFS,P. Hybrid Active Filter for Harmonically Unbalanced Three Phase Three Wire Railway Traction Loads. IEEE Transactions on Power Electronics, v.15, n.4, July. 2000.
- [27] SENINI,S.T. ;WOLFS,P.J. Novel Topology of Unbalanced Load in Single Phase Electric Traction Systems. In:Power Electronics Specialists Conference,2001-PESC'2002- IEEE 33rd Annual,June.2002. Anais. v.3. p.1208-1212. 2002.
- [28] VERDELHO,P. ; MARQUES,G.D. Design and Performance of an Active Power Filter and Unbalanced Current Compensator. In:Industrial Electronics,Control and Instrumentation,Sep.1994. IECON'94,20th International Conference on. Anais eletrônicos. 1994. v.1. p.422-427.
- [29] WATANABE,E. ;AREDES,M. Teoria de Potência Ativa e Reativa Instantânea e Aplicações – Filtros Ativos e FACTS". Tutorial in the CBA'98 (XII Brazilian Automatic Control Conference), Uberlândia, Brazil, Sep.14-18, 1998.
- [30] WATANABE,E. ;AREDES,M. ;AKAGI,H. The p-q theory for active filter control : some problems and solutions. In:XIV Congresso Brasileiro de Automática-CBA,2002.
- [31] WILLEMS,J.L. Current Compensation in Three-Phase Power Systems. ETEP, v.3, n.1, Jan. Feb. 1993.
- [32] ZHANG, G.; XU, Z. A New Real-time Negative and Positive Sequence Componentes Detecting Method Based on Space Vector. In:POWER ENGINEERING SOCIETY WINTER MEETING 2001,Jan.-Feb.2001. Anais eletrônicos. IEEE, v.1. p.275-280.
- [33] Fortescue, C.L. Method of symmetrical co-ordinates applied to the solution of polyphase networks. In:34th Annual Convention of the America Institute of Electrical Engineers. Atlantic City, N.J. , June. 1918.
- [34] CUTRI,R. ; MATAKAS JR.,L. A new instantaneous method for harmonics, positive and negative sequence detection for compensation of distorted currents with

static converters using pulse width modulation. In: 11° ICHQP 11th International Conference on Harmonics and Quality of Power 2004, Lake Placid, New York, September, 2004.

- [35] AHN,S.U.; JARDINI,J.A.; MATAKAS JR.,L.; KOMATSU,W.; MASUDA,M.; SILVA,F.; GALASSI,M.; MARTINZ,F.; COPELIOVICT,H.; OLIVEIRA,M.A.; CAMARGO,J.; ZANETTLE,E.; LIMA,E.; Implementação e testes da geração de referência e controle em um protótipo de restaurador dinâmico de tensão.In: VI SBQEE VI Seminário

Brasileiro sobre Qualidade da Energia Elétrica, Belém, Pará, Brasil, Agosto, 2005.

- [36] IEEE 519-1992 IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems - Institute of Electrical and Electronics Engineers / 01-May-1992 - ISBN: 1559372397.
- [37] CUTRI,R.; MATAKAS JR.,L. A generalized instantaneous method for harmonics, positive and negative sequence detection/extraction. PESC 2007 (IEEE Power Electronics Specialists Conference) – Junho 17-21, Orlando, Flórida/USA